

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0067:231 Page 1 of 1

CATEGORY: Control Unit (Non High Rise)

LISTEE: Siemens Building Technologies Inc, Fire Safety Division, 8 Fernwood Rd, Florham Park, NJ 07932 Contact: Peter Pawchak (973) 593-2662

DESIGN: Models "FireSeeker" FS-100, and FS -100R fire alarm control units. Local, auxiliary, remote station (protected premises), proprietary, central station (protected premises), waterflow and sprinkler supervisory service. Refer to listee's data sheet and control unit's installation instructions for additional detailed product description and operational considerations. System components:

| | |
|----------------------|---|
| FS-100, -100R | Main Control Board |
| FS-MT | Municipal Tie Module |
| FS-232 | RS-232 Interface Board |
| FS-DACT | Digital Alarm Communication Transmitter |
| FS-RD, -RD-R | Remote LCD Annuciation for FS-100 |
| FS-AE, FS-AE-R | Fire Alarm Accessory Enclosure |
| FS-AE-TK, FS-AE-TK-R | Accessory Enclosure Trim Kit |
| FS-SAU | Serial Annunciator Unit |
| FS-SAE16 | Serial Annunciator Extender |
| FS-RU | Serial Relay Unit |
| FS-RE8 | Serial Relay Extender |

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Siemens, model number, rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details. Model FS-100, -100R support both Siemens and System Sensor addressable devices.

NOTE: For Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-0065-168

12-15-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 15, 2002**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**